
Profile/Ph	oto Observatio	n Report			RedZone R 0 B 0 T I C S
Date: Pipe Length (ft P.O.#: Customer:	04/04/2018 :): 144.4	Weather: Owner: Surveyor: Clean Date:	NA Jen Costello 01/01/1900	Coding: Pre Clean: PSR: Shape:	PACP 6.0 No Pre-Cleaning P-707-052-053 C
Street:	S LAKE PARK AVE	& E 13TH ST	Flow Control:	Not Controlled	I
City:	Hobart, IN		Year Renewed:		
Location:	Yard		Tape/Media #:		
Purpose:	Routine Assessme	ent	Dia/Height:	8"	
Use:	Sanitary		Material:	PVC	
Drain Area:	NA		Lining:		
Category:	NA				
Comment:	Flow direction is	marked wrong.			
Location Detai	ls:		Direction of Survey	: Upstream	
US MH:	M-707-053	DS MH: N	1-707-052	Total Length Surveyed (ft	): <b>92.5</b>
0&M Index:	2.50	O&M Quick:	3121	O&M Rating:	5.00
Structural Index:	0.00	Structural Quic	k: 0000	Structural Rating:	0.00
Overall Index:	2.50	Overall Quick:	3121	Overall Rating:	5.00





Code: Description:	AMH Manhole
Distance (ft):	.0
Structural Grade:	0
O&M Grade:	0
Clock Start/From:	
Clock To:	
1st Value:	
2nd Value:	
Value Percent:	
Continuous Index:	
Within 8" of Joint:	NO
Remarks:	M-707-052



Code: MWL Description: Water Level

.0 D D
-
D
-
5.000
NO



Code:	DAE
Description:	Deposits Attached Encrustation

Distance (ft):	24.6
Structural Grade:	0
O&M Grade:	3
Clock Start/From:	8
Clock To:	4
1st Value:	
2nd Value:	
Value Percent:	20.000
Continuous Index:	
Within 8" of Joint:	YES
Remarks:	



Code:	IW
Description:	Infil Weeper

Distance (ft):	24.6
Structural Grade:	0
O&M Grade:	2
Clock Start/From:	8
Clock To:	4
1st Value:	
2nd Value:	
Value Percent:	
Continuous Index:	
Within 8" of Joint:	YES
Remarks:	

Remarks:



Code: Description:	AMH Manhole
Distance (ft):	92.5
Structural Grade:	0
O&M Grade:	0
Clock Start/From:	
Clock To:	
1st Value:	
2nd Value:	
Value Percent:	
Continuous Index:	
Within 8" of Joint:	NO

M-707-053