Profile/Photo Observation Report



Date: 04/04/2018 Weather: Coding: PACP 6.0

Pipe Length (ft): 144.4 Owner: NA Pre Clean: No Pre-Cleaning
P.O.#: Surveyor: Jen Costello PSR: P-707-052-053

Customer: Clean Date: 01/01/1900 Shape: C

Street: FOXCROFT STREET Flow Control: Not Controlled

City: Hobart, IN Year Renewed: Location: Yard Tape/Media #:

Purpose: Routine Assessment Dia/Height: 8"
Use: Sanitary Material: PVC

Drain Area: **NA** Lining:

Category: NA
Comment: Flow direction is marked wrong.

Location Details: Direction of Survey: **Upstream**

US MH: M-707-053 DS MH: M-707-052 Total Length Surveyed (ft): 92.5

3121 2.50 5.00 O&M Index: O&M Quick: O&M Rating: 0.00 0000 0.00 Structural Quick: Structural Rating: Structural Index: 2.50 3121 5.00 Overall Quick: Overall Rating: Overall Index:

Position	Code	Observation	Video (sec)	Grade
52				
0.	AMH	Manhole	10	NA
\0	MWL	Water Level	21	NA
24.6	DAE	Deposits Attached Encrustation	82	M 3
24.6	IW	Infil Weeper	93	M 2
92.5	AMH	Manhole	240	NA
	.0 .0 .0 24.6	052 .0 AMH .0 MWL 24.6 DAE 24.6 IW	.0 AMH Manhole .0 MWL Water Level 24.6 DAE Deposits Attached Encrustation 24.6 IW Infil Weeper	.0 AMH Manhole 10 .0 MWL Water Level 21 24.6 DAE Deposits Attached Encrustation 82 24.6 IW Infil Weeper 93

Code:



Description:	Manhole		
Distance (ft):	.0		
Structural Grade:	0		
O&M Grade:	0		
Clock Start/From:			
Clock To:			
1st Value:			
2nd Value:			
Value Percent:			
Continuous Index:			
Within 8" of Joint:	NO		
Remarks:	M-707-052		

 AMH



Code: MWL

Description: **Water Level**

Distance (ft): .0 Structural Grade: 0 O&M Grade: 0 Clock Start/From:

Clock To:

1st Value: 2nd Value:

Value Percent:

Continuous Index:

Within 8" of Joint:


Remarks:

5.000

NO

Code: DAE

Description: **Deposits Attached Encrustation**



Distance (ft): 24.6 Structural Grade: 0

O&M Grade: 3 Clock Start/From: 8 Clock To: 4


1st Value: 2nd Value:

Value Percent: 20.000

Continuous Index:

Within 8" of Joint: YES

Remarks:



Code: IW

Description: Infil Weeper

Distance (ft): 24.6
Structural Grade: 0
O&M Grade: 2
Clock Start/From: 8
Clock To: 4
1st Value:

2nd Value: Value Percent: Continuous Index:

Within 8" of Joint:

Remarks:

YES



Code: AMH
Description: Manhole

Distance (ft): 92.5
Structural Grade: 0

O&M Grade: 0

Clock Start/From:

Clock To:
1st Value:
2nd Value:
Value Percent:
Continuous Index:

Within 8" of Joint: NO

Remarks: M-707-053