Profile/Photo Observation Report



Date: 03/19/2018 Weather: **PACP 6.0** Coding: Pipe Length (ft): 170.8 Owner: NA Pre Clean: **Not Known** P.O.#: Surveyor: John Kuglmaier PSR: P-709-030-012

Customer: Clean Date: 01/01/1900 Shape: C

Street: WAXWING CIR Flow Control: Not Controlled

City: Hobart, IN Year Renewed:
Location: Yard Tape/Media #:

Purpose: Maintenance Related Dia/Height: 8"
Use: Sanitary Material: PVC

Drain Area: NA Lining:

Category: NA

Comment:

Location Details: Direction of Survey: Upstream

US MH: M-709-012 DS MH: M-709-030 Total Length Surveyed (ft): 169.5

2.00 2900 18.00 O&M Index: O&M Quick: O&M Rating: 0.00 0000 0.00 Structural Quick: Structural Rating: Structural Index: 2.00 2900 18.00 Overall Index: Overall Rating: Overall Quick:

	Position	Code	Observation	Video (sec)	Grade
709-03	30				
	.0	AMH	Manhole	10	NA
	\0	MWL	Water Level	21	NA
	8.4	TF	Tap Factory	50	NA
	10.2	TF	Tap Factory	65	NA
	64.8	DAGS	Deposits Attached Grease	186	M 2
	65.9	TF	Tap Factory	200	NA
ш.	66.0	DAGS	Deposits Attached Grease	212	M 2
	67.5	TF	Tap Factory	226	NA
	/ 118.4	DAZ(S01)	Deposits Attached Other	339	M 2
	130.5	MWL	Water Level	375	NA
	137.7	MWL	Water Level	401	NA
	152.1	DAZ(F01)	Deposits Attached Other	441	M 2
	169.5	AMH	Manhole	487	NA
709 - 0:	12				

Code:



Description:	Manhole		
Distance (ft):	.0		
Structural Grade: O&M Grade:	0		
Clock Start/From:			
Clock To: 1st Value:			
2nd Value:			
Value Percent:			
Continuous Index:			
Within 8" of Joint: Remarks:	NO M-709-030		

AMH



Code: MWL

Description: **Water Level**

Distance (ft): .0 Structural Grade: 0 O&M Grade: 0

Clock Start/From: Clock To:

1st Value: 2nd Value:

Value Percent:

Continuous Index:

Within 8" of Joint:

Remarks:

5.000

NO

Code: TF **Tap Factory** Description:




Distance (ft): 8.4 Structural Grade: 0 O&M Grade: 0 Clock Start/From: 10

Clock To: 1st Value:

Remarks:

4.000

2nd Value: Value Percent: Continuous Index: Within 8" of Joint:



Code: **TF**

Description: Tap Factory

Distance (ft): 10.2
Structural Grade: 0
O&M Grade: 0
Clock Start/From: 2

Clock To:

1st Value: **4.000**

2nd Value: Value Percent: Continuous Index: Within 8" of Joint:

Remarks:



Code: DAGS

Description: Deposits Attached Grease

Distance (ft): 64.8
Structural Grade: 0

O&M Grade: 2

Clock Start/From: 3

Clock To: 5

1st Value: 2

2nd Value:

Value Percent: 5.000

Continuous Index:

Within 8" of Joint: NO

Remarks:



Code: **TF**

Description: Tap Factory

Distance (ft): 65.9
Structural Grade: 0
O&M Grade: 0
Clock Start/From: 10

Clock To:

1st Value:

2nd Value: Value Percent: Continuous Index: Within 8" of Joint:

Remarks:



Description: Deposits Attached Grease

4.000



Distance (ft): 66.0
Structural Grade: 0
O&M Grade: 2
Clock Start/From: 7
Clock To: 9
1st Value:

Value Percent:

Continuous Index:


Within 8" of Joint:

Remarks:

2nd Value:

NO

5.000



Code: **TF**

Description: Tap Factory

Distance (ft): 67.5
Structural Grade: 0
O&M Grade: 0
Clock Start/From: 2

Clock To:

1st Value: **4.000**

2nd Value: Value Percent: Continuous Index: Within 8" of Joint:

Remarks:

2nd Value:



Description: Deposits Attached Other



Distance (ft): 118.4
Structural Grade: 0
O&M Grade: 2
Clock Start/From: 4
Clock To: 8
1st Value:

Value Percent: 5.000
Continuous Index: S01
Within 8" of Joint: NO

Remarks: Mixed materials



Code: MWL

Description: Water Level

Distance (ft): 130.5
Structural Grade: 0
O&M Grade: 0

Clock Start/From: Clock To:

1st Value: 2nd Value:

Value Percent: 15.000

Continuous Index:

Within 8" of Joint:

Remarks:

NO



Code: MWL

Description: Water Level

Distance (ft): 137.7
Structural Grade: 0
O&M Grade: 0

Clock Start/From:

Clock To: 1st Value: 2nd Value:

Value Percent: 25.000

Continuous Index:

Within 8" of Joint: NO

Remarks:



Code: DAZ

Description: Deposits Attached Other

Distance (ft): 152.1
Structural Grade: 0
O&M Grade: 2
Clock Start/From: 4
Clock To: 8

1st Value: 2nd Value:

Value Percent: 5.000
Continuous Index: F01
Within 8" of Joint: NO

Remarks: Mixed materials / Clock positions

vary



Code: AMH
Description: Manhole

Distance (ft): 169.5
Structural Grade: 0
O&M Grade: 0

Clock Start/From:

Clock To:
1st Value:
2nd Value:
Value Percent:
Continuous Index:

Within 8" of Joint: NO

Remarks: M-709-012