## **Profile/Photo Observation Report**

E Randolph St



**Not Controlled** 

Date: 04/23/2018 Weather: Coding: **PACP 6.0** Pipe Length (ft): 225.0 Owner: **City of Hobart** Pre Clean: No Pre-Cleaning P.O.#: 2004 Surveyor: SAN PSR: P-802-021-022 Customer: **Red Zone** Clean Date:

Flow Control:

Shape:

City: **Hobart In** Year Renewed:

Location: **Parking Lot** Tape/Media #: Deliverable 1

Purpose: **Routine Assessment** Dia/Height: **PVC** Use: Sanitary Material:

Northeast Lining: Drain Area:

NA Category:

Street:

Comment: 427-2/Incomplete on reverse setup due to debris.

Lot behind strip mall **Location Details:** Direction of Survey: Upstream

US MH: M-802-21 Total Length Surveyed (ft): DS MH: M-802-022 .1

O&M Index:	0.00	O&M Quick:	0000	O&M Rating:	0.00
Structural Index:	0.00	Structural Quick:	0000	Structural Rating:	0.00
Overall Index:	0.00	Overall Quick:	0000	Overall Rating:	0.00

1 Thursday, May 4, 2023

Position	Code	Observation	Video (sec)	Grade
802-022				
0.	AMH	Manhole	18	NA
0.	MWL	Water Level	43	NA
0.	MGO	General Observation	78	NA
0.	MSA	Abandoned Survey	98	NA
ll				



Code: Description:		AMH Manhole		
Distance (ft)	):	.0		
Structural G	rade:	0		
O&M Grade	:	0		
Clock Start/	From:			
Clock To:				
1st Value:				
2nd Value:				
Value Perce	nt:			
Continuous	Index:			
Within 8" of	Joint:	NO		
Remarks:		M-802-022		

Thursday, May 4, 2023 2



Code: MWL

Description: **Water Level** 

Distance (ft): .0 Structural Grade: 0 O&M Grade: 0

Clock Start/From:

Clock To: 1st Value: 2nd Value:

Value Percent:

Continuous Index:

Within 8" of Joint: NO

10.000

Remarks:



Code: MGO

Description: **General Observation** 

Distance (ft): .0 Structural Grade: 0 O&M Grade: 0 Clock Start/From:

Clock To: 1st Value: 2nd Value:

Value Percent: Continuous Index:

Within 8" of Joint: NO

Remarks: line is 100% restricted by debris

3 Thursday, May 4, 2023



Code: MSA

Description: Abandoned Survey

Distance (ft): .0
Structural Grade: 0
O&M Grade: 0

Clock Start/From:

Clock To: 1st Value: 2nd Value: Value Percent:

Continuous Index: Within 8" of Joint:

Remarks: needs cleaned

NO

Thursday, May 4, 2023 4