Date:	03/29/2018	Weather:		Coding:	PACP 6.0
Pipe Length (ft)	130.9	Owner:	NA	Pre Clean:	Not Known
P.O.#:		Surveyor:	Jen Costello	PSR:	P-803-003-002
Customer:		Clean Date:	01/01/1900	Shape:	С
Street:	HIGH ST		Flow Control:	Not Controlled	
City:	Hobart, IN		Year Renewed:		
Location:	Other		Tape/Media #:		
Purpose:	Not Known		Dia/Height:	10"	
Use:	Sanitary		Material:	VCP	
Drain Area:	NA		Lining:		
Category:	NA				
Comment:					
Location Details	:		Direction of Surve	y: Upstream	
US MH:	M-803-003	DS MH:	M-803-002	Total Length Surveyed (ft	: 28.9
D&M Index:	1.71	O&M Quick:	3123	O&M Rating:	12.00
Structural Index:	3.00	Structural Qu	uick: 3100		3.00
Overall Index:	1.88	Overall Quick			15.00

	Position	Code	Observation	Video (sec)	Grade
M(803-	002				
\square	0.	AMH	Manhole	10	NA
	0	MWL	Water Level	21	NA
	2.0	FL	Fracture Longitudinal	37	S 3
- 11	2.0	DAR	Deposits Attached Ragging	48	M 2
	13.9	RFJ	Roots Fine Joint	84	M 1
- 11	18.9	TFD	Tap Factory Defective	106	M 2
- 11	18.9	RFL	Roots Fine Lateral	117	M 1
- 11	19.9	RFJ	Roots Fine Joint	131	M 1
- 11	27.8	TFD	Tap Factory Defective	158	M 2
5	27.8	RML	Roots Medium Lateral	170	M 3
ecti	28.9	MSA	Abandoned Survey	183	NA
Camera Direction					
M-803-	003				



Code: Description:	AMH Manhole
Distance (ft):	.0
. ,	
Structural Grade:	0
O&M Grade:	0
Clock Start/From:	
Clock To:	
1st Value:	
2nd Value:	
Value Percent:	
Continuous Index:	
Within 8" of Joint:	NO
Remarks:	M-803-002



Code: Description:

Distance (ft): .0 Structural Grade: 0 O&M Grade: 0 Clock Start/From: Clock To: 1st Value: 2nd Value: Value Percent: 30.000 Continuous Index: Within 8" of Joint: NO Remarks:

MWL

Water Level



Code:	FL
Description:	Fracture Longitudinal

Distance (ft):	2.0
Structural Grade:	3
O&M Grade:	0
Clock Start/From:	3
Clock To:	
1st Value:	
2nd Value:	
Value Percent:	
Continuous Index:	
Within 8" of Joint:	YES
Remarks:	



Code:DARDescription:Deposits Attached Ragging

Distance (ft):	2.0
Structural Grade:	0
O&M Grade:	2
Clock Start/From:	11
Clock To:	
1st Value:	
2nd Value:	
Value Percent:	5.000
Continuous Index:	
Within 8" of Joint:	YES
Remarks:	



Code:	RFJ
Description:	Roots Fine Joint
Distance (ft):	13.9
Structural Crades	0

Distance (ft):	13.9
Structural Grade:	0
O&M Grade:	1
Clock Start/From:	12
Clock To:	
1st Value:	
2nd Value:	
Value Percent:	
Continuous Index:	
Within 8" of Joint:	YES
Remarks:	



Code:TFDDescription:Tap Factory Defective

Distance (ft):	18.9
Structural Grade:	0
O&M Grade:	2
Clock Start/From:	2
Clock To:	
1st Value:	4.000
2nd Value:	
Value Percent:	
Continuous Index:	
Within 8" of Joint:	
Remarks:	ROOTS



Code:	RFL
Description:	Roots Fine Lateral

Distance (ft):	18.9
Structural Grade:	0
O&M Grade:	1
Clock Start/From:	2
Clock To:	
1st Value:	
2nd Value:	
Value Percent:	
Continuous Index:	
Within 8" of Joint:	NO
Remarks:	



Code:**RFJ**Description:**Roots Fine Joint**

Distance (ft):	19.9
Structural Grade:	0
O&M Grade:	1
Clock Start/From:	8
Clock To:	4
1st Value:	
2nd Value:	
Value Percent:	
Continuous Index:	
Within 8" of Joint:	YES
Remarks:	



Code: Description:	TFD Tap Factory Defective
Distance (ft):	27.8
Structural Grade:	0
O&M Grade:	2
Clock Start/From:	10
Clock To:	
1st Value:	4.000
2nd Value:	
Value Percent:	
Continuous Index:	
Within 8" of Joint:	
Remarks:	ROOTS



Code:RMLDescription:Roots Medium Lateral

Distance (ft):	27.8
Structural Grade:	0
O&M Grade:	3
Clock Start/From:	6
Clock To:	10
1st Value:	
2nd Value:	
Value Percent:	40.000
Continuous Index:	
Within 8" of Joint:	NO
Remarks:	

Code: Description: MSA Abandoned Survey



Distance (ft):	28.9
Structural Grade:	0
O&M Grade:	0
Clock Start/From:	
Clock To:	
1st Value:	
2nd Value:	
Value Percent:	
Continuous Index:	
Within 8" of Joint:	NO
Remarks:	ROOTS