
Profile/Ph	oto Observatio	n Report				RedZone
Date:	04/04/2018	Weather:			Coding:	PACP 6.0
Pipe Length (ft	): <b>175.2</b>	Owner:	NA		Pre Clean:	Not Known
P.O.#:		Surveyor:	Jen Costell	о	PSR:	P-803-051-042
Customer:		Clean Date	: <b>01/01/190</b>	0	Shape:	С
Street:	E 40TH AVE & N I	ELLY ST Flow Control:		Not Controlled		
City:	Hobart, IN		Year Renew	ed:		
Location:	Other		Tape/Media	#:		
Purpose:	Not Known		Dia/Height:		12"	
Use:	Sanitary		Material:		VCP	
Drain Area:	NA		Lining:			
Category:	NA					
Comment:						
Location Detail	ls:		Direction of	Survey:	Downstream	
US MH:	M-803-042	DS MH:	M-803-051	To	tal Length Surveyed (ft):	106.8
0&M Index:	2.00	O&M Quick	:	2600	O&M Rating:	12.00
tructural Index:	4.00	Structural Q	uick:	4100	Structural Rating:	4.00
Overall Index:	2.29	Overall Quid	:k:	4126	Overall Rating:	16.00





Code: Description:	AMH Manhole
Distance (ft):	.0
Structural Grade:	0
O&M Grade:	0
Clock Start/From:	
Clock To:	
1st Value:	
2nd Value:	
Value Percent:	
Continuous Index:	
Within 8" of Joint:	NO
Remarks:	M-803-042



Code: MWL Description: Water Level

Distance (ft):	.0
Structural Grade:	0
O&M Grade:	0
Clock Start/From:	
Clock To:	
1st Value:	
2nd Value:	
Value Percent:	5.000
Continuous Index:	
Within 8" of Joint:	NO
Remarks:	



Code:	DAZ
Description:	Deposits Attached Other

Distance (ft):	13.0
Structural Grade:	0
O&M Grade:	2
Clock Start/From:	7
Clock To:	5
1st Value:	
2nd Value:	
Value Percent:	10.000
Continuous Index:	S01
Within 8" of Joint:	NO
Remarks:	



Code:DAZDescription:Deposits Attached Other

Distance (ft):	42.6
Structural Grade:	0
O&M Grade:	2
Clock Start/From:	7
Clock To:	5
1st Value:	
2nd Value:	
Value Percent:	10.000
Continuous Index:	F01
Within 8" of Joint:	NO
Remarks:	



Code:	FM
Description:	Fracture Multiple
Distance (ft)	84.0

Distance (ft):	84.0	
Structural Grade:	4	
O&M Grade:	0	
Clock Start/From:	12	
Clock To:	3	
1st Value:		
2nd Value:		
Value Percent:		
Continuous Index:		
Within 8" of Joint:	YES	
Remarks:		



Code: Description: MSA Abandoned Survey

Distance (ft):	106.8
Structural Grade:	0
O&M Grade:	0
Clock Start/From:	
Clock To:	
1st Value:	
2nd Value:	
Value Percent:	
Continuous Index:	
Within 8" of Joint:	NO
Remarks:	unknown