Profile/Photo Observation Report

Other

Location:



Date: 03/26/2018 Weather: Coding: **PACP 6.0** Pipe Length (ft): 157.3 Owner: NA Pre Clean: **Not Known** P.O.#: **Justin Gonzales** PSR: P-803-055-029 Surveyor:

Customer: Clean Date: 01/01/1900 Shape: C

Street: E RAND ST & N LIBERTY CT Flow Control: Not Controlled

City: Hobart, IN Year Renewed:

Purpose: Not Known Dia/Height: 10"
Use: Sanitary Material: VCP

Use: Sanitary Material: Volume Drain Area: NA Lining:

Category: NA

Comment:

Location Details: Direction of Survey: Downstream

US MH: M-803-055 DS MH: M-803-029 Total Length Surveyed (ft): 153.6

2.00 2300 6.00 O&M Index: O&M Quick: O&M Rating: 3.33 10.00 Structural Index: Structural Quick: Structural Rating: 2.67 16.00 Overall Index: Overall Quick: Overall Rating:

Tape/Media #:

	Code	Observation	Video (sec)	Grade
03-055				
0.	FM	Fracture Multiple	11	S 4
0.	AMH	Manhole	22	NA
0.	MWL	Water Level	33	NA
46.3	MGO	General Observation	138	NA
82.9	TF	Tap Factory	222	NA
82.9	DAZ	Deposits Attached Other	234	M 2
94.7	DAZ	Deposits Attached Other	269	M 2
95.8	TFA	Tap Factory Active	284	NA
136.1	FL(S01)	Fracture Longitudinal	378	S 3
143.9	DAZ	Deposits Attached Other	405	M 2
144.5	FL(F01)	Fracture Longitudinal	418	S 3
± 9	. =(. 0 =)		710	33
153.6	AMH	Manhole	447	NA
1111		-		



Code: FM
Description: Fracture Multiple

Distance (ft): .0 Structural Grade: 4 O&M Grade: 0 Clock Start/From: 12 Clock To: 5 1st Value: 2nd Value: Value Percent: Continuous Index: Within 8" of Joint: Remarks:



Code: AMH
Description: Manhole

Distance (ft): .0
Structural Grade: 0
O&M Grade: 0
Clock Start/From:
Clock To:
1st Value:
2nd Value:
Value Percent:
Continuous Index:

Within 8" of Joint: NO

Remarks: M-803-055



Code: MWL
Description: Water Level

Distance (ft): .0
Structural Grade: 0
O&M Grade: 0
Clock Start/From:
Clock To:
1st Value:

Value Percent: 5.000

Continuous Index:

Within 8" of Joint: NO

Remarks:

2nd Value:



Code: MGO

Description: General Observation

Distance (ft): 46.3
Structural Grade: 0

O&M Grade: 0

Clock Start/From:

Clock To: 1st Value: 2nd Value: Value Percent: Continuous Index:

Within 8" of Joint: NO

Remarks: TOILET TISSUE



Code: **TF**

Description: Tap Factory

Distance (ft): 82.9
Structural Grade: 0

O&M Grade: 0

Clock Start/From: 2

Clock To:

1st Value: **4.000**

2nd Value: Value Percent: Continuous Index: Within 8" of Joint:



Code: DAZ

Description: Deposits Attached Other

Distance (ft): 82.9
Structural Grade: 0
O&M Grade: 2
Clock Start/From: 7
Clock To: 10

1st Value: 2nd Value:

Value Percent: 5.000

Continuous Index:

Within 8" of Joint:

Remarks:

NO



Code: DAZ

Description: Deposits Attached Other

Distance (ft): 94.7
Structural Grade: 0

O&M Grade: 2

Clock Start/From: 3

Clock To: 5

1st Value:

2nd Value:

Value Percent: 5.000

Continuous Index:

Within 8" of Joint: NO



Code: TFA

Description: Tap Factory Active

4.000


Distance (ft): 95.8
Structural Grade: 0
O&M Grade: 0
Clock Start/From: 10

Clock To:


1st Value:

2nd Value: Value Percent: Continuous Index: Within 8" of Joint:

Remarks:



Description: Fracture Longitudinal



Distance (ft): 136.1
Structural Grade: 3
O&M Grade: 0

Clock Start/From: 12

Clock To: 1st Value: 2nd Value: Value Percent:

Continuous Index: **S01** Within 8" of Joint: **YES**



Code: DAZ

Description: Deposits Attached Other

Distance (ft): 143.9
Structural Grade: 0
O&M Grade: 2
Clock Start/From: 4
Clock To: 5
1st Value:

2nd Value:

Value Percent: 5.000

Continuous Index:

Within 8" of Joint: YES
Remarks: MUD



Code: FL

Description: Fracture Longitudinal

Distance (ft): 144.5
Structural Grade: 3
O&M Grade: 0
Clock Start/From: 12

Clock To: 1st Value: 2nd Value: Value Percent:

Continuous Index: F01
Within 8" of Joint: YES



Code: AMH
Description: Manhole

Distance (ft): 153.6
Structural Grade: 0
O&M Grade: 0

Clock Start/From: Clock To: 1st Value: 2nd Value: Value Percent:

Continuous Index: Within 8" of Joint:

Remarks: M-803-029

NO