

Profile/Photo Observation Report



Date:	05/04/2018	Weather:		Coding:	PACP 4.2
Pipe Length (ft):	21.0	Owner:	City of Hobart	Pre Clean:	No Pre-Cleaning
P.O.#:	2004	Surveyor:	SAN	PSR:	P-904-052-062
Customer:	Red Zone	Clean Date:		Shape:	C

Street:	178 N Hobart Rd	Flow Control:	Not Controlled
City:	Hobart In	Year Renewed:	
Location:	Yard	Tape/Media #:	Deliverable 1
Purpose:	Routine Assessment	Dia/Height:	18"
Use:	Sanitary	Material:	VCP
Drain Area:	Northeast	Lining:	
Category:	NA		
Comment:	445-1/Reverse setup due to debris.		
Location Details:	Grass at edge of street	Direction of Survey:	Downstream
US MH:	M-804-062	DS MH:	M-804-052
		Total Length Surveyed (ft):	3.0

O&M Index:	0.00	O&M Quick:	0000	O&M Rating:	0.00
Structural Index:	0.00	Structural Quick:	0000	Structural Rating:	0.00
Overall Index:	0.00	Overall Quick:	0000	Overall Rating:	0.00

	Position	Code	Observation	Video (sec)	Grade
	.0	AMH	Manhole	14	NA
	.0	MWL	Water Level	71	NA
	.0	MGO	General Observation	108	NA
	1.6	MGO	General Observation	194	NA
	3.0	MGO	General Observation	269	NA
	3.0	MSA	Abandoned Survey	306	NA



Code: **AMH**
 Description: **Manhole**

Distance (ft): **.0**
 Structural Grade: **0**
 O&M Grade: **0**
 Clock Start/From:
 Clock To:
 1st Value:
 2nd Value:
 Value Percent:
 Continuous Index:
 Within 8" of Joint: **NO**
 Remarks: **M-804-062**



Code: **MWL**
Description: **Water Level**

Distance (ft): **.0**
Structural Grade: **0**
O&M Grade: **0**
Clock Start/From:
Clock To:
1st Value:
2nd Value:
Value Percent: **35.000**
Continuous Index:
Within 8" of Joint: **NO**
Remarks:



Code: **MGO**
Description: **General Observation**

Distance (ft): **.0**
Structural Grade: **0**
O&M Grade: **0**
Clock Start/From:
Clock To:
1st Value:
2nd Value:
Value Percent:
Continuous Index:
Within 8" of Joint: **NO**
Remarks: **infil in manhole**



Code: **MGO**
Description: **General Observation**

Distance (ft): **1.6**
Structural Grade: **0**
O&M Grade: **0**
Clock Start/From:
Clock To:
1st Value:
2nd Value:
Value Percent:
Continuous Index:
Within 8" of Joint: **NO**
Remarks: **debris under flow**



Code: **MGO**
Description: **General Observation**

Distance (ft): **3.0**
Structural Grade: **0**
O&M Grade: **0**
Clock Start/From:
Clock To:
1st Value:
2nd Value:
Value Percent:
Continuous Index:
Within 8" of Joint: **NO**
Remarks: **camera will not pass debris**



Code:	MSA
Description:	Abandoned Survey
Distance (ft):	3.0
Structural Grade:	0
O&M Grade:	0
Clock Start/From:	
Clock To:	
1st Value:	
2nd Value:	
Value Percent:	
Continuous Index:	
Within 8" of Joint:	NO
Remarks:	unable to complete in reverse setup line needs cleaned