Profile/Ph	oto Observation	n Report			
Date:	03/21/2018	Weather:		Coding:	PACP 6.0
Pipe Length (ft	z): <b>251.2</b>	Owner:	NA	Pre Clean:	Not Known
P.O.#:		Surveyor:	Selasie Honu	PSR:	P-808-009-008
Customer:		Clean Date:	01/01/1900	Shape:	с
Street:	Oak		Flow Control:	Not Controlled	
City:	Hobart, IN		Year Renewed:		
Location:	Light Highway		Tape/Media #:		
Purpose:	Maintenance Rela	ted	Dia/Height:	12"	
Use:	Sanitary		Material:	PVC	
Drain Area:	NA		Lining:		
Category:	NA				
Comment:	flow is incorrect.				
Location Detai	ls:		Direction of Sur	vey: Upstream	
US MH:	M-808-008	DS MH:	M-808-009	Total Length Surveyed (ft)	2 <b>49.8</b>
D&M Index:	2.25	O&M Quick:	312	23 O&M Rating:	9.00
Structural Index	0.00	Structural Q	uick: 000		0.00
Overall Index:	2.25	Overall Quic	244		9.00

		Position	Code	Observation	Video (sec)	Grade
М	808-0	09				
	$ \leq $	0. /	AMH	Manhole	10	NA
	ш.	.0	MWL	Water Level	21	NA
		39.4	TF	Tap Factory	113	NA
		52.0	DAE	Deposits Attached Encrustation	152	M 3
		53.7	TFD	Tap Factory Defective	168	M 2
	F	107.4	TF	Tap Factory	291	NA
	ш.	120.6	TF	Tap Factory	333	NA
	ш.	120.6	DAGS	Deposits Attached Grease	345	M 2
	ш.	174.3	TF	Tap Factory	468	NA
5		188.4	TF	Tap Factory	512	NA
ecti		227.6	TF	Tap Factory	605	NA
ni Din	/	241.7	TF	Tap Factory	649	NA
Camera Direction	ш.	241.7	DAGS	Deposits Attached Grease	660	M 2
Cai	ш.	249.8	AMH	Manhole	690	NA
_						
- <b>†</b>						



Code: Description:	AMH Manhole
Distance (ft):	.0
Structural Grade:	0
O&M Grade:	0
Clock Start/From:	
Clock To:	
1st Value:	
2nd Value:	
Value Percent:	
Continuous Index:	
Within 8" of Joint:	NO
Remarks:	M-808-009

M(808-)008



Code: MWL Description: Water Level

Distance (ft):	.0
Structural Grade:	0
O&M Grade:	0
Clock Start/From:	
Clock To:	
1st Value:	
2nd Value:	
Value Percent:	5.000
Continuous Index:	
Within 8" of Joint:	NO
Remarks:	



TF Tap Factory
39.4
0
0
2
4.000



Code:DAEDescription:Deposits Attached Encrustation

Distance (ft):	52.0
Structural Grade:	0
O&M Grade:	3
Clock Start/From:	7
Clock To:	10
1st Value:	
2nd Value:	
Value Percent:	15.000
Continuous Index:	
Within 8" of Joint:	NO
Remarks:	


Code:	TFD
Description:	Tap Factory Defective
Distance (ft):	53.7
Structural Grade:	0
O&M Grade:	2
Clock Start/From:	10
Clock To:	
1st Value:	4.000
2nd Value:	
Value Percent:	
Continuous Index:	
Within 8" of Joint:	
Remarks:	dae



Code:	TF
Description:	Tap Factory
Distance (ft):	107.4
Structural Grade:	0
O&M Grade:	0
Clock Start/From:	2
Clock To:	
1st Value:	4.000
2nd Value:	
Value Percent:	
Continuous Index:	
Within 8" of Joint:	NO
Remarks:	



Code: Description:	TF Tap Factory
Distance (ft): Structural Grade: O&M Grade: Clock Start/From: Clock To: 1st Value: 2nd Value: Value Percent:	120.6 0 0 11 4.000
Continuous Index: Within 8" of Joint: Remarks:	



Code:DAGSDescription:Deposits Attached Grease

Distance (ft):	120.6
Structural Grade:	0
O&M Grade:	2
Clock Start/From:	8
Clock To:	4
1st Value:	
2nd Value:	
Value Percent:	5.000
Continuous Index:	
Within 8" of Joint:	NO
Remarks:	



Code: Description:	TF Tap Factory
Distance (ft): Structural Grade: O&M Grade: Clock Start/From: Clock To: 1st Value:	174.3 0 0 2 4.000
2nd Value: Value Percent: Continuous Index: Within 8" of Joint: Remarks:	



Code:	TF
Description:	Tap Factory

188.4
0
0
10
4.000



Code: Description:	TF Tap Factory
Distance (ft):	227.6
Structural Grade:	0
O&M Grade:	0
Clock Start/From:	2
Clock To:	
1st Value:	4.000
2nd Value:	
Value Percent:	
Continuous Index:	
Within 8" of Joint:	
Remarks:	



Code:	TF
Description:	Tap Factory

241.7
0
0
11
4.000



scription:	Deposits Attached Grease
scription:	Deposits Attached

Distance (ft):	241.7
Structural Grade:	0
O&M Grade:	2
Clock Start/From:	8
Clock To:	4
1st Value:	
2nd Value:	
Value Percent:	5.000
Continuous Index:	
Within 8" of Joint:	NO
Remarks:	



Code: AMH Description: Manhole

Distance (ft):	249.8
Structural Grade:	0
O&M Grade:	0
Clock Start/From:	
Clock To:	
1st Value:	
2nd Value:	
Value Percent:	
Continuous Index:	
Within 8" of Joint:	NO
Remarks:	M-808-008