Profile/Photo Observation Report



Date: 03/25/2018 Weather: **PACP 6.0** Coding: Pipe Length (ft): 85.4 Owner: NA Pre Clean: **Not Known** P.O.#: **Byrd Fitzgerald** PSR: P-902-045-078 Surveyor:

Customer: Clean Date: 01/01/1900 Shape: C

Street: saint joesph pl Flow Control: Not Controlled

City: Hobart, IN Year Renewed:
Location: Other Tape/Media #:

Purpose: Not Known Dia/Height: 10"
Use: Sanitary Material: PVC

Drain Area: NA Lining:

Category: NA

Comment:

Location Details: Direction of Survey: Upstream

US MH: M-902-045 DS MH: M-902-078 Total Length Surveyed (ft): 82.7

3926 2.60 39.00 O&M Index: O&M Quick: O&M Rating: 0.00 0000 0.00 Structural Quick: Structural Rating: Structural Index: 3926 2.60 39.00 Overall Index: Overall Quick: Overall Rating:

.0 AMH Manhole 22 .0 MWL Water Level 33 .0 DAGS(S01) Deposits Attached Grease 44 30.5 DAGS(F01) Deposits Attached Grease 116 42.9 MWL Water Level 153 44.3 DSF(F02) Deposits Settled Fine 167		Position	Code	Observation	Video (sec)	Grade
.0 DSF(S02) Deposits Settled Fine 10 .0 AMH Manhole 22 .0 MWL Water Level 33 .0 DAGS(S01) Deposits Attached Grease 44 30.5 DAGS(F01) Deposits Attached Grease 116 42.9 MWL Water Level 153 44.3 DSF(F02) Deposits Settled Fine 167	902-078	3				
.0 MWL Water Level 33 .0 .0 DAGS(S01) Deposits Attached Grease 44 .1 .1 .2 .2 .1 .2 .2 .2	· /.		DSF(S02)	Deposits Settled Fine	10	M 3
	\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\	.0	AMH	Manhole	22	NA
30.5 DAGS(F01) Deposits Attached Grease 116 42.9 MWL Water Level 153 44.3 DSF(F02) Deposits Settled Fine 167	\\\\.	.0	MWL	Water Level	33	NA
42.9 MWL Water Level 153 44.3 DSF(F02) Deposits Settled Fine 167	/-	.0	DAGS(S01)	Deposits Attached Grease	44	M 2
44.3 DSF(F02) Deposits Settled Fine 167	1	30.5	DAGS(F01)	Deposits Attached Grease	116	M 2
	[]	42.9	MWL	Water Level	153	NA
82.7 AMH Manhole 255	/[4	44.3	DSF(F02)	Deposits Settled Fine	167	M 3
		82.7	AMH	Manhole	255	NA

Code:



Description:	Deposits Settled Fine		
Distance (ft):	.0		
Structural Grade:	0		
O&M Grade:	3		
Clock Start/From:	4		
Clock To:	8		
1st Value:			
2nd Value:			
Value Percent:	20.000		
Continuous Index:	S02		
Within 8" of Joint:	NO		
Remarks:			

DSF



Code: AMH
Description: Manhole

Distance (ft): .0
Structural Grade: 0
O&M Grade: 0
Clock Start/From:
Clock To:
1st Value:

2nd Value: Value Percent: Continuous Index:

Within 8" of Joint:

Remarks: M-902-078

NO

0.000



Code: MWL
Description: Water Level

Distance (ft): .0
Structural Grade: 0
O&M Grade: 0
Clock Start/From:
Clock To:
1st Value:

2nd Value: Value Percent:

Continuous Index:

Within 8" of Joint: NO

Remarks:



Code: DAGS

Description: Deposits Attached Grease

Distance (ft): .0
Structural Grade: 0
O&M Grade: 2
Clock Start/From: 7
Clock To: 5
1st Value:

2nd Value:

Value Percent: 5.000
Continuous Index: S01
Within 8" of Joint: NO

Remarks:

Code: DAGS

Description: Deposits Attached Grease



Distance (ft): 30.5
Structural Grade: 0

O&M Grade: 2


Clock Start/From: 7

Clock To: 5

1st Value: 2nd Value:

Value Percent: 5.000
Continuous Index: F01
Within 8" of Joint: NO

Remarks:



Code: MWL

Description: Water Level

Distance (ft): 42.9
Structural Grade: 0

O&M Grade: 0

Clock Start/From:

Clock To: 1st Value: 2nd Value:


Value Percent: 5.000

Continuous Index:

Within 8" of Joint:

Remarks:

NO



Code: **DSF**

Description: Deposits Settled Fine

Distance (ft): 44.3
Structural Grade: 0
O&M Grade: 3
Clock Start/From: 4
Clock To: 8
1st Value:

Value Percent: 20.000
Continuous Index: F02
Within 8" of Joint: NO

Remarks:

2nd Value:



Code: AMH
Description: Manhole

Distance (ft): 82.7
Structural Grade: 0

O&M Grade: 0

Clock Start/From:

Clock To: 1st Value: 2nd Value: Value Percent: Continuous Index:

Within 8" of Joint: NO

Remarks: **M-902-045**