Profile/Photo Observation Report



Date: 03/30/2018 Weather: Coding: **PACP 6.0** Pipe Length (ft): 194.9 Owner: NA Pre Clean: **Not Known**

P.O.#: Jen Costello PSR: P-903-023-022 Surveyor: Customer: 01/01/1900 Clean Date: Shape:

ALLEY BETWEEN BRANDT ST & RUSH Flow Control: **Not Controlled** Street:

City: Hobart, IN Year Renewed: Other Tape/Media #:

Purpose: **Not Known** Dia/Height: 10" **PVC** Use: Sanitary Material:

NA Lining: Drain Area:

NA Category:

Comment:

Location:

Location Details: Direction of Survey: **Downstream**

US MH: M-903-023 Total Length Surveyed (ft): M-903-022 DS MH: 73.1

2.00 2100 2.00 O&M Index: O&M Quick: O&M Rating: 3.00 3200 6.00 Structural Index: Structural Quick: Structural Rating: 3221 2.67 8.00 Overall Index: Overall Quick: Overall Rating:

	Position	Code	Observation	Video (sec)	Grade
.0 AMH Manhole 10 N .0 MWL Water Level 21 N 1.2 CM Crack Multiple 35 S 27.4 TF Tap Factory 99 N 31.1 CM Crack Multiple 118 S 66.4 TFA Tap Factory Active 201 N 69.8 IW Infil Weeper 220 N	03-022				
1.2 CM Crack Multiple 35 S		AMH	Manhole	10	NA
27.4 TF Tap Factory 99 N 31.1 CM Crack Multiple 118 S 66.4 TFA Tap Factory Active 201 N 69.8 IW Infil Weeper 220 N	0.	MWL	Water Level	21	NA
31.1 CM	1.2	CM	Crack Multiple	35	S 3
66.4 TFA Tap Factory Active 201 N 69.8 IW Infil Weeper 220 N	27.4	TF	Tap Factory	99	NA
69.8 IW Infil Weeper 220 N	31.1	CM	Crack Multiple	118	S 3
· · · · · · · · · · · · · · · · · · ·	66.4	TFA	Tap Factory Active	201	NA
73.1 MSA Abandoned Survey 238 N	69.8	IW	Infil Weeper	220	M 2
	73.1	MSA	Abandoned Survey	238	NA

Code:



Description:	Manhole	
Distance (ft):	.0	
Structural Grade:	0	
O&M Grade:	0	
Clock Start/From:		
Clock To:		
1st Value:		
2nd Value:		
Value Percent:		
Continuous Index:		
Within 8" of Joint:	NO	
Remarks:	M-903-022	

AMH



Code: MWL
Description: Water Level

Distance (ft): .0
Structural Grade: 0
O&M Grade: 0

Clock Start/From:

Clock To: 1st Value: 2nd Value:

Value Percent: 10.000

Continuous Index:

Within 8" of Joint: NO

Remarks:




Code: CM

Description: Crack Multiple

Distance (ft): 1.2
Structural Grade: 3
O&M Grade: 0
Clock Start/From: 8
Clock To: 4
1st Value:
2nd Value:
Value Percent:
Continuous Index:

Within 8" of Joint: YES

Remarks:



Code: **TF**

Description: Tap Factory

Distance (ft): 27.4
Structural Grade: 0
O&M Grade: 0
Clock Start/From: 10

Clock To:

1st Value: **4.000**

2nd Value: Value Percent: Continuous Index: Within 8" of Joint:

Remarks:




Code: CM

Description: Crack Multiple

Distance (ft): 31.1
Structural Grade: 3
O&M Grade: 0
Clock Start/From: 8
Clock To: 4
1st Value:
2nd Value:
Value Percent:
Continuous Index:

Within 8" of Joint: YES

Remarks:



Code: TFA

Description: Tap Factory Active

4.000

Distance (ft): 66.4
Structural Grade: 0

O&M Grade: 0

Clock Start/From: 3

Clock To:

1st Value:

2nd Value: Value Percent: Continuous Index: Within 8" of Joint:

Remarks:

Code: IW

Description: Infil Weeper



Distance (ft): 69.8
Structural Grade: 0
O&M Grade: 2
Clock Start/From: 8
Clock To: 9
1st Value:
2nd Value:
Value Percent:

Continuous Index: Within 8" of Joint:

thin 8" of Joint: YES

Remarks:



Code: MSA

Description: Abandoned Survey

Distance (ft): 73.1
Structural Grade: 0

O&M Grade: 0

Clock Start/From:

Clock To: 1st Value: 2nd Value: Value Percent: Continuous Index:

Within 8" of Joint: NO

Remarks: debris under water