Profile/Photo Observation Report



Date: 03/20/2018 Weather: **PACP 6.0** Coding: Pipe Length (ft): 328.8 Owner: NA Pre Clean: **Not Known** P.O.#: Surveyor: **JUSTIN GONZALES** PSR: P-903-057-056

Customer: Clean Date: 01/01/1900 Shape: C

Street: OFF N HOBART RD Flow Control: Not Controlled

City: Hobart, IN Year Renewed:
Location: Other Tape/Media #:

Purpose: Not Known Dia/Height: 10"
Use: Sanitary Material: PVC

Drain Area: **NA** Lining:

Category: NA

Comment:

Location Details: Direction of Survey: Downstream

US MH: M-903-056 DS MH: M-903-057 Total Length Surveyed (ft): 251.8

2.02 **312**I 103.00 O&M Index: O&M Quick: O&M Rating: 2.00 2100 2.00 Structural Quick: Structural Rating: Structural Index: 2.02 **312**I 105.00 Overall Index: Overall Quick: Overall Rating:

	Position	Code	Observation	Video (sec)	Grade
903-	056				
	0.	AMH	Manhole	10	NA
		MWL	Water Level	21	NA
	\\.0	DAZ(S01)	Deposits Attached Other	33	M 2
ш	17.4	TF	Tap Factory	80	NA
	84.5	MWL	Water Level	226	NA
	127.9	TF	Tap Factory	326	NA
	165.5	MWL	Water Level	414	NA
	182.8	MWL	Water Level	460	NA
	209.5	MWL	Water Level	525	NA
	234.6	MWLS	Water Level Sag	586	S 2
	251.8	АМН	Manhole	632	NA
	251.8	DAZ(F01)	Deposits Attached Other	643	M 2
	1				

Code:



Description:	Manhole
Distance (ft):	.0
Structural Grade:	0
O&M Grade:	0
Clock Start/From:	
Clock To:	
1st Value:	
2nd Value:	
Value Percent:	
Continuous Index:	
Within 8" of Joint:	NO
Remarks:	M-903-056

 AMH



Code: MWL

Description: **Water Level**

Distance (ft): .0 Structural Grade: 0 O&M Grade: 0

Clock Start/From:

Clock To: 1st Value: 2nd Value:

Value Percent:


Continuous Index:

Within 8" of Joint:

Remarks:

10.000

NO



Code: DAZ

Description: **Deposits Attached Other**

Distance (ft): .0 Structural Grade: 0 O&M Grade: 2 Clock Start/From: 7 Clock To: 5 1st Value: 2nd Value:

Value Percent: 5.000 Continuous Index: **S01** Within 8" of Joint: YES

Remarks: WANDER



Code: **TF**

Description: Tap Factory


Distance (ft): 17.4
Structural Grade: 0
O&M Grade: 0
Clock Start/From: 3

Clock To:

1st Value: **4.000**

2nd Value: Value Percent: Continuous Index: Within 8" of Joint:

Remarks:



Code: MWL

Description: Water Level

Distance (ft): 84.5
Structural Grade: 0
O&M Grade: 0

Clock Start/From:

Clock To: 1st Value: 2nd Value:

Value Percent: 20.000

Continuous Index:

Within 8" of Joint: NO

Remarks:



Code: **TF**

Description: Tap Factory

Distance (ft): 127.9
Structural Grade: 0
O&M Grade: 0
Clock Start/From: 3

Clock To:

1st Value: **4.000**

2nd Value: Value Percent: Continuous Index: Within 8" of Joint:

Remarks:



Code: MWL

Description: Water Level

Distance (ft): 165.5
Structural Grade: 0
O&M Grade: 0

Clock Start/From:

Clock To: 1st Value: 2nd Value:

Value Percent: **30.000**

Continuous Index:

Within 8" of Joint: NO

Remarks:



Code: MWL

Description: Water Level

Distance (ft): 182.8
Structural Grade: 0
O&M Grade: 0

Clock Start/From:

Clock To: 1st Value: 2nd Value:

Value Percent: 5.000

Continuous Index:

Within 8" of Joint:

Remarks:

NO



Code: MWL

Description: Water Level

Distance (ft): 209.5
Structural Grade: 0
O&M Grade: 0

Clock Start/From:

Clock To: 1st Value: 2nd Value:

Value Percent: 30.000

Continuous Index:

Within 8" of Joint: NO

Remarks:



Code: MWLS

Description: Water Level Sag

Distance (ft): 234.6
Structural Grade: 2
O&M Grade: 3
Clock Start/From:

Clock To: 1st Value: 2nd Value:

Value Percent: 25.000

Continuous Index:

Within 8" of Joint:

Remarks:

NO



Code: AMH
Description: Manhole

Distance (ft): 251.8
Structural Grade: 0
O&M Grade: 0

Clock Start/From:

Clock To: 1st Value: 2nd Value: Value Percent: Continuous Index:

Within 8" of Joint: NO

Remarks: M-903-057



Code: DAZ

Description: Deposits Attached Other

Distance (ft): 251.8
Structural Grade: 0
O&M Grade: 2
Clock Start/From: 7
Clock To: 5

1st Value: 2nd Value:

Value Percent: 5.000
Continuous Index: F01
Within 8" of Joint: YES

Remarks: WANDER