


## Profile/Photo Observation Report



Date:	<b>04/20/2018</b>	Weather:		Coding:	<b>PACP 4.2</b>
Pipe Length (ft):	<b>388.9</b>	Owner:	<b>City of Hobart</b>	Pre Clean:	<b>No Pre-Cleaning</b>
P.O.#:	<b>2004</b>	Surveyor:	<b>SAN</b>	PSR:	<b>P-904-005-006</b>
Customer:	<b>Red Zone</b>	Clean Date:		Shape:	<b>C</b>

Street:	<b>E Hickey St</b>	Flow Control:	<b>Not Controlled</b>
City:	<b>Hobart In</b>	Year Renewed:	
Location:	<b>Light Highway</b>	Tape/Media #:	<b>Deliverable 1</b>
Purpose:	<b>Routine Assessment</b>	Dia/Height:	<b>18"</b>
Use:	<b>Sanitary</b>	Material:	<b>PVC</b>
Drain Area:	<b>Northeast</b>	Lining:	
Category:	<b>NA</b>		
Comment:	<b>423-1/DSMH 006 is covered.</b>		
Location Details:	<b>Center of street</b>	Direction of Survey:	<b>Downstream</b>
US MH:	<b>M-904-005</b>	DS MH:	<b>M-904-006</b>
		Total Length Surveyed (ft):	<b>388.9</b>

O&M Index:	<b>3.00</b>	O&M Quick:	<b>3D00</b>	O&M Rating:	<b>87.00</b>
Structural Index:	<b>2.00</b>	Structural Quick:	<b>2D00</b>	Structural Rating:	<b>58.00</b>
Overall Index:	<b>2.50</b>	Overall Quick:	<b>3D2D</b>	Overall Rating:	<b>145.00</b>

	Position	Code	Observation	Video (sec)	Grade
	.0	AMH	Manhole	18	NA
	.0	MWL	Water Level	34	NA
	131.3	TF	Tap Factory	258	NA
	244.9	MWLS(S01)	Water Level Sag	405	S 2
	388.9	MWLS(F01)	Water Level Sag	616	S 2
	388.9	AMH	Manhole	670	NA



Code: **AMH**  
Description: **Manhole**

Distance (ft): **.0**  
Structural Grade: **0**  
O&M Grade: **0**  
Clock Start/From:  
Clock To:  
1st Value:  
2nd Value:  
Value Percent:  
Continuous Index:  
Within 8" of Joint: **NO**  
Remarks: **M-904-005**



Code:	<b>MWL</b>
Description:	<b>Water Level</b>
Distance (ft):	<b>.0</b>
Structural Grade:	<b>0</b>
O&M Grade:	<b>0</b>
Clock Start/From:	
Clock To:	
1st Value:	
2nd Value:	
Value Percent:	<b>15.000</b>
Continuous Index:	
Within 8" of Joint:	<b>NO</b>
Remarks:	



Code:	<b>TF</b>
Description:	<b>Tap Factory</b>
Distance (ft):	<b>131.3</b>
Structural Grade:	<b>0</b>
O&M Grade:	<b>0</b>
Clock Start/From:	<b>1</b>
Clock To:	
1st Value:	<b>4.000</b>
2nd Value:	
Value Percent:	
Continuous Index:	
Within 8" of Joint:	<b>NO</b>
Remarks:	



Code:	<b>MWLS</b>
Description:	<b>Water Level Sag</b>
Distance (ft):	<b>244.9</b>
Structural Grade:	<b>2</b>
O&M Grade:	<b>3</b>
Clock Start/From:	
Clock To:	
1st Value:	
2nd Value:	
Value Percent:	<b>25.000</b>
Continuous Index:	<b>S01</b>
Within 8" of Joint:	<b>NO</b>
Remarks:	



Code:	<b>MWLS</b>
Description:	<b>Water Level Sag</b>
Distance (ft):	<b>388.9</b>
Structural Grade:	<b>2</b>
O&M Grade:	<b>3</b>
Clock Start/From:	
Clock To:	
1st Value:	
2nd Value:	
Value Percent:	<b>25.000</b>
Continuous Index:	<b>F01</b>
Within 8" of Joint:	<b>NO</b>
Remarks:	



Code:	<b>AMH</b>
Description:	<b>Manhole</b>
Distance (ft):	<b>388.9</b>
Structural Grade:	<b>0</b>
O&M Grade:	<b>0</b>
Clock Start/From:	
Clock To:	
1st Value:	
2nd Value:	
Value Percent:	
Continuous Index:	
Within 8" of Joint:	<b>NO</b>
Remarks:	<b>M-904-006</b>