
Profile/Ph	oto Observation	Report				RedZone
Date:	04/17/2018	Weather:			Coding:	PACP 6.0
Pipe Length (ft	): <b>18.2</b>	Owner:	NA		Pre Clean:	Not Known
P.O.#:		Surveyor:	Jen Costel	lo	PSR:	P-904-026-025
Customer:		Clean Date:	01/01/190	00	Shape:	С
Street:	CLEVELAND TERR		Flow Contro	ol:	Not Controlled	
City:	Hobart, IN		Year Renew	ed:		
Location:	Other		Tape/Media	a #:		
Purpose:	Not Known		Dia/Height:		10"	
Use:	Sanitary		Material:		VCP	
Drain Area:	NA		Lining:			
Category:	NA					
Comment:						
Location Detai	ls:		Direction of	Survey:	Upstream	
US MH:	M-904-026	DS MH:	M-904-025	Т	otal Length Surveyed (ft)	15.6
0&M Index:	2.00	O&M Quick:		2300	O&M Rating:	6.00
tructural Index	0.00	Structural Qu	uick:	0000	Structural Rating:	0.00
Overall Index:	2.00	Overall Quick	<:	2300	Overall Rating:	6.00





Code: Description:	AMH Manhole
Distance (ft):	.0
Structural Grade:	0
O&M Grade:	0
Clock Start/From:	
Clock To:	
1st Value:	
2nd Value:	
Value Percent:	
Continuous Index:	
Within 8" of Joint:	NO
Remarks:	M-904-025



Code: MWL Description: Water Level

Distance (ft): .0 Structural Grade: 0 O&M Grade: 0 Clock Start/From: Clock To: 1st Value: 2nd Value: Value Percent: 40.000 Continuous Index: Within 8" of Joint: NO Remarks:

Code:	DAGS
Description:	Deposits Attached Grease

Distance (ft):	.0
Structural Grade:	0
O&M Grade:	2
Clock Start/From:	8
Clock To:	4
1st Value:	
2nd Value:	
Value Percent:	5.000
Continuous Index:	S01
Within 8" of Joint:	NO
Remarks:	



Code:DAGSDescription:Deposits Attached Grease

Distance (ft):	14.0
Structural Grade:	0
O&M Grade:	2
Clock Start/From:	8
Clock To:	4
1st Value:	
2nd Value:	
Value Percent:	5.000
Continuous Index:	F01
Within 8" of Joint:	NO
Remarks:	



Code:	AMH
Description:	Manhole

Distance (ft):	15.6
Structural Grade:	0
O&M Grade:	0
Clock Start/From:	
Clock To:	
1st Value:	
2nd Value:	
Value Percent:	
Continuous Index:	
Within 8" of Joint:	NO
Remarks:	M-904-026