## **Profile/Photo Observation Report**



Date: 04/13/2018 Weather: **PACP 6.0** Coding: Pipe Length (ft): 300.0 Owner: NA Pre Clean: **Not Known** P.O.#: Jen Costello PSR: P-904-034-033 Surveyor:

Customer: Clean Date: 01/01/1900 Shape: C

Street: CLEVELAND TERR Flow Control: Not Controlled

City: Hobart, IN Year Renewed:
Location: Other Tape/Media #:

Purpose: Not Known Dia/Height: 8"
Use: Sanitary Material: VCP

Drain Area: NA Lining:

Category: NA
Comment:

Location Details: Direction of Survey:

US MH: M-904-034 DS MH: M-904-033 Total Length Surveyed (ft): 293.3

542E 2.31 83.00 O&M Rating: O&M Index: O&M Quick: 0.00 0000 0.00 Structural Quick: Structural Rating: Structural Index: 2.31 542E 83.00 Overall Index: Overall Quick: Overall Rating:

**Downstream** 

Position	Code	Observation	Video (sec)	Grade
004-034				
.0	АМН	Manhole	10	NA
0.	MWL	Water Level	21	NA
0.	OBZ(S01)	Obstacle Other	32	M 5
15.8	OBZ(F01)	Obstacle Other	75	M 5
15.8	MWL	Water Level	86	NA
108.1	TFA	Tap Factory Active	282	NA
/136.6	DAGS(S02)	Deposits Attached Grease	351	M 2
//145.2	TF	Tap Factory	380	NA
//217.3	TF	Tap Factory	536	NA
239.2	TF	Tap Factory	592	NA
275.2	RFJ	Roots Fine Joint	675	M 1
290.9	TF	Tap Factory	718	NA
292.5	DAE	Deposits Attached Encrustation	733	M 5
293.3	MSA	Abandoned Survey	746	NA
293.3	DAGS(F02)	Deposits Attached Grease	757	M 2

Code:



Description:	Manhole		
Distance (ft):	.0		
Structural Grade:	0		
O&M Grade:	0		
Clock Start/From:			
Clock To:			
1st Value:			
2nd Value:			
Value Percent:			
Continuous Index:			
Within 8" of Joint:	NO		
Remarks:	M-904-034		

AMH



Code: MWL Description: **Water Level** 

Distance (ft): .0 Structural Grade: 0 O&M Grade: 0

Clock Start/From:

Clock To: 1st Value: 2nd Value:

Value Percent: 30.000

Continuous Index:

Within 8" of Joint:

NO

Remarks:



Code: OBZ

Description: **Obstacle Other** 

Distance (ft): .0 Structural Grade: 0 O&M Grade: 5 Clock Start/From: 3 Clock To: 9 1st Value: 2nd Value:

40.000 Value Percent: Continuous Index: **S01** Within 8" of Joint: NO Remarks: misc



Code: OBZ

Description: Obstacle Other

Distance (ft): 15.8
Structural Grade: 0
O&M Grade: 5
Clock Start/From: 3
Clock To: 9
1st Value:

2nd Value:

Value Percent: 40.000
Continuous Index: F01
Within 8" of Joint: NO
Remarks: misc



Code: MWL

Description: Water Level

Distance (ft): 15.8
Structural Grade: 0

O&M Grade: **0** Clock Start/From:

Clock To: 1st Value: 2nd Value:

Value Percent: 5.000

Continuous Index:

Within 8" of Joint: NO



Code: TFA

Description: Tap Factory Active

Distance (ft): 108.1
Structural Grade: 0
O&M Grade: 0
Clock Start/From: 9

Clock To:

1st Value: **4.000** 

2nd Value: Value Percent: Continuous Index: Within 8" of Joint:

Remarks:



Code: DAGS

Description: Deposits Attached Grease

Distance (ft): 136.6
Structural Grade: 0
O&M Grade: 2
Clock Start/From: 8
Clock To: 4
1st Value:
2nd Value:

Value Percent: 5.000
Continuous Index: S02
Within 8" of Joint: NO



Code: **TF** 

Description: Tap Factory


Distance (ft): 145.2
Structural Grade: 0
O&M Grade: 0
Clock Start/From: 10

Clock To:

1st Value: **4.000** 

2nd Value: Value Percent: Continuous Index: Within 8" of Joint:

Remarks:



Code: **TF** 


Description: Tap Factory

Distance (ft): 217.3
Structural Grade: 0
O&M Grade: 0
Clock Start/From: 3

Clock To:

1st Value: **4.000** 

2nd Value: Value Percent: Continuous Index: Within 8" of Joint:



Code: **TF** 

Description: Tap Factory

Distance (ft): 239.2
Structural Grade: 0
O&M Grade: 0
Clock Start/From: 10

Clock To:

1st Value:

2nd Value: Value Percent: Continuous Index: Within 8" of Joint:

Remarks:

Code: RFJ

Description: Roots Fine Joint

4.000



Distance (ft): 275.2 Structural Grade: 0

O&M Grade: 1
Clock Start/From: 11

Clock To: 1st Value: 2nd Value: Value Percent: Continuous Index:

Within 8" of Joint: YES



Code: **TF** 

Description: Tap Factory

Distance (ft): 290.9
Structural Grade: 0
O&M Grade: 0
Clock Start/From: 2

Clock To:

1st Value: **4.000** 

2nd Value: Value Percent: Continuous Index: Within 8" of Joint:

Remarks:



Code: DAE

Description: Deposits Attached Encrustation

Distance (ft): 292.5
Structural Grade: 0
O&M Grade: 5
Clock Start/From: 7
Clock To: 5
1st Value:

2nd Value:

Value Percent: 60.000

Continuous Index:

Within 8" of Joint: YES



Code: MSA

Description: Abandoned Survey

Distance (ft): 293.3
Structural Grade: 0
O&M Grade: 0

Clock Start/From:

Clock To: 1st Value: 2nd Value: Value Percent: Continuous Index:

Within 8" of Joint: NO Remarks: dae



Code: DAGS

Description: Deposits Attached Grease

Distance (ft): 293.3
Structural Grade: 0
O&M Grade: 2
Clock Start/From: 8
Clock To: 4
1st Value:
2nd Value:

Value Percent: 5.000
Continuous Index: F02
Within 8" of Joint: NO